

AIRSYS Cooling Technologies Inc.  
7820 Reidville Rd. Suite 100, Greer, SC 29651

Subject: **Sound Level Determination of an AIRSYS Heat Pump  
Installed in a Goleta CA School District Classroom**

DL Acoustics has determined the A-Weighted sound levels of a wall-mounted heat pump in a typical furnished but unoccupied\* relocatable (e.g., “portable”) classroom in the Goleta, CA School District. The unit tested is identified below.

Manufacturer: Airsys Refrigeration Engineering Technology  
Product Name: COM4T  
Model: CV36H2A-AWAXX  
Serial Number: F20218050077

Name and Location of School: Hollister Elementary, 4950 Anita Lane, Santa Barbara CA, 93111

A-Weighted sound level determinations are reported for the following four operating modes:

Modes of Operation for A-Weighted Sound Level Determinations

- (1) high-speed, cooling mode
- (2) low speed, cooling mode
- (3) ventilation fan only (no cooling or heating)
- (4) unit off (classroom ambient noise only)

**Table of Results**

<b>Operating Mode</b>	<b>Measured LAeq</b> (includes room ambient noise)	<b>Calculated LAeq</b> (Corrected for room ambient noise)
High speed fan Cooling mode	40.5 dBA	<b>39.3 dBA</b>
Low speed fan Cooling mode	37.0 dBA	<b>36.7 dBA</b>
Fan on compressor off	35.2 dBA	<b>34.6 dBA</b>
Room ambient noise Unit off	24.4 dBA	-

AIRSYS Cooling Technologies Inc.  
7820 Reidville Rd. Suite 100, Greer, SC 29651

**Microphone location**

A tripod mounted ¼" microphone was positioned 5 ft. above the classroom floor, 10 ft. from the unit face, on a line parallel to the floor that passes through the geometrical center of the unit's fan.

**Calibration**

Calibrated measuring instruments employed were: Bruel & Kjaer (B&K) 2270 sound analyzer, ¼" B&K microphone, B&K model 4231 field calibrator. Apparatus is calibrated annually by a qualified independent third party. Calibration documents are available for inspection at DL Acoustics.

If you have any questions about this report please don't hesitate to contact me by phone at (714) 373-3050 or by email at [dlubman@dlacoustics.com](mailto:dlubman@dlacoustics.com).

Sincerely yours,



David Lubman, FASA, FINCE  
Acoustical Consultant  
Orange County Certification #200524